AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Result of Inter Lock pavers

IS: 516 - 1959 | Date: 25-05-2020

Name of Work : Comprehensive Development works in ward No. 03 Attur

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Consultant	aartn Associates
Contractor	B.B Umesh (S.M.L.P Asphats)
Customer Reference	EE(PROJECT)/YNK ZONE/WO/173/2019-20
Source of Sample	Sample supplied by Agency
Sample Type	Inter Lock pavers
Date of Test	25-05-2020

Sl. No	Details	Flexural Strength	Compressive Strength	Aveerage Compressive Strength
		mpa	N/mm^2	N/mm^2
1	Paver Block	4.01	36.24	36.67
2	Paver Block	4.12	37.78	
3	Paver Block	3.96	35.99	

Remarks :

For AARTN ASSOCIATES

Authorised Signatory.

Scanned by TapScanner

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Result of Inter Lock pavers

IS: 516 - 1959	Date:	26-05-2020

Name of Work : Comprehensive Development works in ward No. 03 Attur

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Consultant	aartn Associates
Contractor	B.B Umesh (S.M.L.P Asphats)
Customer Reference	EE(PROJECT)/YNK ZONE/WO/173/2019-20
Source of Sample	Sample supplied by Agency
Sample Type	Inter Lock pavers
Date of Test	26-05-2020

Sl. No	Details	Flexural Strength	Compressive Strength	Aveerage Compressive Strength
		mpa	N/mm^2	N/mm^2
1	Paver Block	3.99	37.05	37.48
2	Paver Block	4.10	38.59	
3	Paver Block	4.04	36.80	

Remarks :

AARTN ASSOCIATES
Authorised Signatory

Scanned by TapScanner

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Result of Inter Lock pavers

IS: 516 - 1959	Date:	26-05-2020

Name of Work : Comprehensive Development works in ward No. 03 Attur

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Consultant	aartn Associates
Contractor	B.B Umesh (S.M.L.P Asphats)
Customer Referenc	EE(PROJECT)/YNK ZONE/WO/173/2019-20
Source of Sample	Sample supplied by Agency
Sample Type	Inter Lock pavers
Date of Test	26-05-2020

Sl. No	Details	Flexural Strength	Compressive Strength	Aveerage Compressive Strength
		mpa	N/mm^2	N/mm^2
1	Paver Block	4.22	38.14	38.57
2	Paver Block	4.33	39.68	
3	Paver Block	4.27	37.89	

Remarks :

AARTN ASSOCIATES
Authorised Signatory

Scanned by TapScanner